

# **BLANK PAGE**



IS: 6598 - 1972 (Reaffirmed 2010)

## Indian Standard

# SPECIFICATION FOR CELLULAR CONCRETE FOR THERMAL INSULATION

**Third Reprint AUGUST 2006** (Including Amendment No. 1 & 2)

UDC 662.998: 666.973.6

 $@ \ \textit{Copyright} \ 1972 \\$ 

BUREAU OF INDIAN STANDARDS MANAK BHAVAN, 9 BAHADUR SHAH ZAFAR MARG NEW DELHI 110002

Gr 2 November 1972

### AMENDMENT NO. 2 AUGUST 2000 TO

# IS 6598: 1972 SPECIFICATION FOR CELLULAR CONCRETE FOR THERMAL INSULATION

- [ Page 4, clause 4.2 ( see also Amendment No. 1 ) ]— Substitute the following for the existing clause:
- **'4.2 Density** The average bulk density of the material shall be as given below when tested in accordance with the method prescribed in 4 of IS 5688: 1982t:

Grade	Density, kg/m <sup>3</sup>
A	Minimum 320
В	321 to 400
С	401 to 500'

(  $Page 4, footnote \ marked \dagger$  ) — Substitute the following for the existing footnote:

'†Methods of lest for preformed block-type and pipe covering type thermal insulation ( first revision ).'

[ Page 5, clause **4.3** ( see also Amendment No. 1, line 3 ) ] — Substitute '5688 : 1982\*' for 'IS : 5688 - 1970\*'.

(  $\textit{Page 5, footnote marked} \,\, \text{'*'} \,\,)$  — Substitute the following for the existing footnote:

'\*Methods of test for preformed block-type and pipe covering type thermal insulation (first revision).'

(CHD 27)

Printed at Prabhat Offset Press, New Delhi-2

### AMENDMENT NO. 1 AUGUST 1981

### TO

# IS:6598-1972 SPECIFICATION FOR CELLULAR CONCRETE FOR THERMAL INSULATION

## <u>Alterations</u>

(Page 4, clause 4.2) - Substitute the following for the existing clause:

'4.2 Density - The average bulk density of the three grades of the material shall be as given below when tested in accordance with the method prescribed in 4 of IS:5688-1970†:

Grade	Density, kg/m <sup>3</sup>
A	Up to 320
В	321 to 400
С	401 to 500

(Page 5, clause 4.3) - Substitute the following for the existing clause:

'4.3 <u>Crushing Strength</u> - The crushing strength of dry cellular concrete shall be as given below when tested in accordance with the method prescribed in 6 of IS:5688-1970\*.

Grade	strength,	$Min, kg/cm^2$
	Type 1	Type 2
A	7.0	2.5
В	12.0	4.5
C	20.0	8.0

(CDC 37)

## Indian Standard

# SPECIFICATION FOR CELLULAR CONCRETE FOR THERMAL INSULATION

### Thermal Insulation Materials Sectional Committee, CDC 37

Chairman	Representing
***************************************	
SHRI T. D. BANSAL	National Physical Laboratory (CSIR), New Delhi
Members	
SHRIM, BALA SUBRAMANIAM	BASF India Ltd, Bombay
DR B. K. BANERJEE	Fertilizer Corporation of India Ltd, New Delhi
DR H. C. ROY ( Alternate )	Ī
SHRI M. B. L. BHATNAGAR	Insulation Manufacturers', Distributors' and Contractors' Association Ltd, Bombay
SHRI A. K. CHATTERJI	Central Building Research Institute (CSIR), Roorkee
DR K. R. RAO (Alternate)	
CHEMIST & METALLURGIST -II,	Railway Board (Ministry of Railways)
RDSO, LUCKNOW	
SHRI M. H. GAJENDRADKAR	Hindustan Steel Ltd, Ranchi
SHRIS. K. MUKHERJEE ( Alterna	
SHRI G. K. KABRA	Hyderabad Allwyn Metal Works Ltd, Hyderabad
SHRI S. R. KHANNA	Directorate General of Technical Development, New Delhi
SHRIR. PARIKSHIT (Alternate)	
SHRI M. G. KUTTY	Hindustan Shipyard Ltd, Visakhapatnam
SHRIK. B. MISTRY (Alternate)	Indian Oil Corporation Ltd ( Pafinarias and Dina
SHRI S. K. NAYAK	Indian Oil Corporation Ltd ( Refineries and Pipeline Division), New Delhi
SHRIJ. D. CHOUDHURY ( Alterna	
SHRI R. P. PUNJ	Punj Sons Private Ltd, New Delhi
SHRI Y . P . PUNJ (Alternate) DR B . C . RAYCKAUDHURI	Control Machanical Engineering Descend Institute
	Central Mechanical Engineering Research Institute (GSIR), Durgapur
SHRI S. B. SARBAR	Ministry of Petroleum and Chemicals & Mines and
SHRI N. R. SAWHNEY	Metals, New Delhi National Insulation Manufacturers' Association, New Delhi
SHRI B. L. SEN	Indian Oxygen Ltd, Calcutta
SHRI D. S. MADAM ( Alternate )	
DR S. P. SUKHATME	Indian Institute of Technology, Bombay
SHRI V. A. SURA	Newkem Products Corporation, Bombay
SHRI P. K. AMIN (Alternate)	

(Continued on page 2)

BUREAU OF INDIAN STANDARDS MANAK BHAVAN. 9 BAHADUR SHAH ZAFAR MARG NEW DELHI 110002

(Continued from page 1)

Member

DR A. VASUDEV

SHHI A. SKARIF ( Alternate ) SHRI D. DAS GUPTA,

Director (Chem)

Representing

Fibreglass Pilkington Ltd, Bombay

Director General, ISI (*Ex-officio Member*)

Secretary

SHRI P. S. ARORA Assistant Director (Chem), ISI

Panel for Cast and Moulded Thermal Insulation Products, CDC 37: P4

Convener

SHRI N. K. D. CHOUDHURY

Member

SHRI B. CHATTERJEE

DR H. C. ROY ( Alternate ) SHRI C. L. KASLIVTAL

SHRI V. A. SURA

Central Building Research Institute (CSIR), Roorkee

Fertilizer Corporation of India Ltd, New Delhi

Hindustan Housing Factory Ltd, New Delhi Newkem Products Corporation, Bombay

## Indian Standard

# SPECIFICATION FOR CELLULAR CONCRETE FOR THERMAL INSULATION

### 0. FOREWORD

- **0.1** This Indian Standard was adopted by the Indian Standards Institution on 30 June 1972, after the draft finalized by the Thermal Insulation Materials Sectional Committee had been approved by the Chemical Division Council.
- **0.2** Cellular concrete is a versatile thermal insulation material on account of its light weight and high thermal insulation. Its versatility is due to its resistance to sulphate action, resistance to alternate cooling and thawing (when high pressure steam cured) and due to its resistance to penetration of water.
- **0.3** When cast *in-situ*, it can be applied over flat roofs as thermal insulation material.
- **0.4** For the purpose of deciding whether a particular requirement of this standard is complied with, the final value, observed or calculated, expressing the result of a test or analysis, shall be rounded off in accordance with IS: 2-1960\*. The number of significant places retained in the rounded off value should be the same as that of the specified value in this standard.

#### 1. SCOPE

**1.1** This standard prescribes the requirements and the methods of sampling and test for cellular concrete for thermal insulation.

#### 2. TYPES AND GRADES

**2.1 Types** — There shall be two types of the material depending on the manner of manufacture, namely:

Type 1 — High pressure steam cured (autoclaved) material in the form of precast blocks.

<sup>\*</sup>Rules for rounding off numerical values ( revision ).

- Type 2 Materials cured under natural conditions (that is, under ambient pressure and temperature) by water. The material may be either cast *in-situ* or may be in the form of precast blocks.
- **2.2 Grades** Each of these two types of the material shall have three grades, namely:

*Grade A* — Light weight cellular concrete;

Grade B — Medium weight cellular concrete; and

*Grade C* — Heavy weight cellular concrete.

#### 3. MATERIALS

- **3.1 Aggregate** A variety of silicious fines, such as ground quartz, sand, shale, fly ash and granulated slag may be used in the manufacture of cellular concrete.
- **3.2 Binders** Portland cement conforming to IS: 269-1967\* or lime shall be used
- **3.3 Gassing Agents** Organic foaming agents based on resin soap, glue, surface active agents, or fine aluminium powder, zinc, dust, calcium carbide, calcium hypochlorite, etc, may be used for gassing the concrete.
- **3.4 Water** The water used for making the concrete shall be clean and free from any matter injurious to the durability of cellular concrete.

### 4. REQUIREMENTS

- **4.1 Description** Cellular concrete is a light weight concrete formed by producing gas or air bubbles in a cement slurry or a cement-sand slurry.
- **4.2 Density** The average bulk density of the three grades of the material shall be as given below when tested in accordance with the method prescribed in **4** of IS: 5688-1970†:

Grade	Density	
A	Up to $300 \text{ kg/m}^3$	
В	$301 \text{ to } 400 \text{ kg/m}^3$	
C	$401 \text{ to } 500 \text{ kg/m}^3$	

<sup>\*</sup> Specification for ordinary, rapid-hardening and low heat Portland cement ( second revision).

<sup>†</sup>Method of trst for preformed block-type and pipe covering-type thermal insulation.

**4.3 Crushing Strength** — The crushing strength of dry cellular concrete shall be as given below when tested in accordance with the method as prescribed in 6 of IS: 5688-1970\*:

Grade	Strength, kg/cm2^	
	Type 1	Type 2
A	7.0	4.5
В	12	6.0
C	20	9.0

- **4.4 Capillary Absorption** The capillary absorption shall not exceed 20 percent in case of Type 1 cellular concrete when tested in accordance with the method prescribed in Appendix A.
- **4.5 Thermal Conductivity** The thermal conductivity of the material shall be as given below when determined in accordance with the method prescribed in IS: 3346-1966†:

Grade	Thermal Conductivity in mW/cm deg at 50°C Mean Temperature, Max	
A	0.7	
В	0.85	
C	1.0	

- **4.6 Dimensions** The dimensions of the Type 1 and Type 2 precast cellular concrete blocks shall be either 50 or 60 cm in length; 20, 25 or 30 cm in width; and 7.5, 10, 15, 25 or 40 cm in thickness.
- **4.6.1** A tolerance of  $\pm$  3 percent shall be allowed on width and height and  $\pm$  1 percent on thickness.

#### 5. MARKING

- **5.1** Each block shall be marked with the manufacturer's identification mark or initials and the type and grade of the material.
  - **5.1.1** The product may also be marked with Standard Mark.

The use of the Standard Mark is governed by the provisions of the *Bureau of Indian Standards Act*, 1986 and the Rules and Regulations made thereunder. The details of conditions under which the licence for the use of Standard Mark may be granted to manufactures or producers may be obtained from the Bureau of Indian Standards.

<sup>\*</sup>Methods of lest for preformed block-type and pipe-covering type thermal insulation. †Method for the determination of thermal conductivity of thermal insulation materials (two slab, guarded hot-plate method).

#### 6. SAMPLING

**6.1** The method of sampling shall be as prescribed in Appendix B.

# APPENDIX A (Clause 4.4)

#### CAPILLARY ABSORPTION TEST

#### A.1. TEST SPECIMENS

**A-1.1** Three test specimens  $4 \times 4$  cm base and 16 cm height shall be prepared.

#### A.2. PROCEDURE

**A-2.1** Dry the specimens in an oven at  $105 \pm 5^{\circ}\text{C}$  and weigh them. Place them on their bases in a water-bath with the water level 1 cm above the base of the specimen. The specimen shall be weighed a few times during the test. Allow them to stand for 48 hours in the water and determine their masses.

#### A-3. CALCULATION

Capillary absorption, percent by mass  $=\frac{w}{W} \times 100$ 

where

w = increase in mass in g of the specimen, and W = mass in g of the specimen after drying.

# APPENDIX B (Clause 6.1)

### SAMPLING OP CELLULAR CONCRETE BLOCKS

#### B-1 LOT

**B-1.1** In a consignment, cellular concrete of the same type and grade and manufactured approximately in the same period shall be grouped to form a lot. If it is in the form of blocks, a lot shall be made up of not more

than 1 000 blocks. If the material is *in.silu*, not more than 10 tonnes of material shall constitute a lot. If the material is transported in lorries and received as such, the material in a lorry (or vehicle) load may conveniently be termed as a lot.

#### **B.2. SCALE OF SAMPLING**

- **B-2.1** Each lot shall be tested for all the requirements of this specification.
- **B-2.2** If the material is received in bulk, samples shall be drawn from different portions so as to be representative of the lot. It is recommended that at least 20 increments, each weighing about 1 kg be taken from the bulk and kept for conducting various tests.
- **B-2.3** If the lot is made up of precast blocks, the number of blocks to be sampled depends upon the size of the lot and shall be in accordance with col 1 and 2 of Table 1.
- **B-2.3.1** The sample blocks shall be selected at random with the help of random number tables. For guidance IS: 4905-1968\* may be referred.

TABLE 1 SCALE OF SAMPLING FOR CELLULAR CONCRETE BLOCKS

	(Clause B-2.3)	
LOT SIZE	SAMPLE SIZE ( BLOCKS TO BE SAMPLED )	PERMISSIBLE NO. OF DEFECTIVES (VISUAL AND DIMENSIONAL REQUIREMENTS)
N	n	a
(1)	(2)	(3)
Up to 100	5	0
101 to 300	8	0
301 ,, 500	13	0
501 ,, 1 000	20	1

#### **B.3. NUMBER OF TESTS AND CRITERIA FOR CONFORMITY**

- **B-3.1 Visual and Dimensional Requirements** In respect of visual and dimensional characteristics (**4.6**), the sample blocks selected according to **B-2** shall be examined. The lot shall be accepted only if the number of defective blocks in the sample does not exceed the permissible number (*a*) given in col 3 of Table 1.
- **B-3.2 Preparation of Samples for Other Tests**—In case of the material in bulk form, the increments shall be grouped into four portions

<sup>\*</sup>Methods for random sampling.

and the material in each portion shall be combined thoroughly to give a test sample. There will thus be four test samples to be used for different tests. In the case of precast blocks four test samples shall be prepared from the sample blocks selected under **B-2**.

- **B-3.3 Density and Crushing Strength** Four tests shall be conducted for each of the two characteristics on test samples or blocks mentioned in **B-3.2.** No failure shall occur if the lot is to be accepted.
- **B-3.4 Thermal Cenductivity** One test shall be conducted for this characteristics on test samples prepared under **B-3.2.** The test shall not fail for acceptance of the lot.
- **B-3.5 Capillary Absorption** One test shall be conducted on any one of the test samples and the lot shall be accepted if the test result complies with the requirement in **4.4**.

### **BUREAU OF INDIAN STANDARDS**

#### Headquarters:

Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 110002

E-mail: bis@vsnl.com website: http://www.bis.org.in

Central Laboratory: Plot No. 20/9, Site IV, Sahibabad Industrial Area. SAHIBABD 201010	Telephone
110t No. 20/9, She iv, Sambabad industrial Area. Sambabb 201010	2770032
Regional Offices:	
Central: Manak Bhavan, 9 Bahadur Shah Zafar Marg, New Delhi 110002	23237617
*Eastern: 1/14 CIT Scheme VII M, V.I.P. Road Kankurgachi, KOLKATA 700054	23378662
Northern: SCO 335-336, Sector 34-A, Chandigarh 160022	603843
Southern: C.I.T. Campus, IV Cross Road, CHENNAI 600113	254 19 84
Western: Manakalaya, E9, MIDC, Behind Marol Telephone Exchange,	2832 92 95
Andheri (East), MUMBAI 400093	2032 72 73
Branch offices:	
'Pushpak' Nurmohamed Shaikh Marg, Khanpur, AHMEDABAD 360001	560 13 48
Peenya Industrial Area, 1st Stage, Bangalore-Tumkur Road, BANGALORE	839 49 55
Commercial-cum-office Complex, opp. Dushera Maidan, Arera Colony,	
Bittan Market, BHOPAL 462016	242 34 52
62/63, Ganga Nagar, Unit VI, BHUBANESHWAR 751001	240 3139
5 <sup>TH</sup> Floor, Kovai Towers, 44 Bala Sundaram Road, COIMBATORE 641018	221 0141
SCO 21, Sector 12, Faridabad 121007	2292175
Savitri Complex,116 G.T. Road Ghaziabad 201001	2861498
53/5 Ward No. 29, R.G. Baraua Road 5 by-lane, Apurba Sinha Path	2541137
GUWAHATI 781003	23 11137
5-8-56C L.N. Gupta Marg, Nampally Station Road, HYBERABAD 500001	23201084
E-52. Chitranjan Marg, C-Scheme, JAIPUR 302001	2973879
117/418 B Sarvodaya Nagar, KANPUR 208005	2218774
Sethi Bhavan: 2 <sup>nd</sup> Floor, Behind Leela Cinema, Naval Kishore Road,	2215698
LUCKNOW 226001	2213070
NIT Building, Second Floor, Gokulpat Market, NAGPUR 440010	2525171
Mahavir Bhavan, First Floor, Ropar Road, NALAGARH 174101	221451
Patliputra Industrial Estate, PATNA 800013	2262808
First Floor, Plot Nos 657-660, Market Yard, Gultkdi, PUNE 411037	4268659
"Sahajanand House" 3 <sup>rd</sup> Floor, Bhaktinagar Circle, 80 Feet Road,	2378251
RAJKOT 360002	2370231
T.C. No. 14/1421, University P.O. Palayam, THIRUVANANTHAPURAM 695034	2322104
1st Floor, Udyog Bhavan, VUDA, Siripuram Junction, VISHAKHAPATNAM-03	2712833
	2,12033
Sales Office is at 5 Chowringhee Approach, P.O. Princep Street, Kolkata 700072	22371085
Sales Office is at Novelty Chambers, Grant Road, MUMBAI 400007	23096528
	23070320